


Polaire



Coefficients d'utilisation

R	77	75	73	71	55	53	33	00	DRR
K0.8	68	64	61	59	63	61	60	58	76
1.0	71	67	65	63	67	64	64	61	81
1.5	75	72	70	68	71	69	69	66	87
2.0	77	75	74	72	74	73	72	70	92
2.5	78	77	76	75	76	75	74	72	95
3.0	79	78	78	77	77	76	75	74	97
4.0	80	80	79	79	78	78	77	75	99
5.0	81	80	80	80	79	79	77	76	100

Courbe limite de luminance




Diagramme UGR

Corrected UGR values (at 1930 lm bare lamp luminous flux)												
Reflect.: ceiling/cav walls work pl. Room dim x y		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30	0.30
		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30	0.30
		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
		viewed crosswise					viewed endwise					
2H	2H	18.0	18.6	18.2	18.9	19.1	18.0	18.6	18.2	18.9	19.1	
	3H	17.8	18.4	18.1	18.7	19.0	17.8	18.4	18.1	18.7	19.0	
	4H	17.8	18.3	18.1	18.6	18.9	17.8	18.3	18.1	18.6	18.9	
	6H	17.7	18.2	18.0	18.5	18.8	17.7	18.2	18.0	18.5	18.8	
	8H	17.7	18.1	18.0	18.5	18.8	17.6	18.1	18.0	18.5	18.8	
	12H	17.6	18.1	18.0	18.4	18.8	17.6	18.1	18.0	18.4	18.8	
4H	2H	17.8	18.3	18.1	18.6	18.9	17.8	18.3	18.1	18.6	18.9	
	3H	17.6	18.1	18.0	18.4	18.8	17.6	18.1	18.0	18.4	18.8	
	4H	17.5	17.9	17.9	18.3	18.7	17.5	17.9	17.9	18.3	18.7	
	6H	17.4	17.8	17.9	18.2	18.6	17.4	17.8	17.9	18.2	18.6	
	8H	17.4	17.7	17.8	18.1	18.6	17.4	17.7	17.8	18.1	18.6	
	12H	17.4	17.7	17.8	18.1	18.5	17.4	17.7	17.8	18.1	18.5	
8H	4H	17.4	17.7	17.8	18.1	18.6	17.4	17.7	17.8	18.1	18.6	
	6H	17.3	17.6	17.8	18.0	18.5	17.3	17.6	17.8	18.0	18.5	
	8H	17.3	17.5	17.8	18.0	18.5	17.3	17.5	17.8	18.0	18.5	
	12H	17.2	17.4	17.7	17.9	18.4	17.2	17.4	17.7	17.9	18.4	
12H	4H	17.4	17.7	17.8	18.1	18.5	17.4	17.7	17.8	18.1	18.5	
	6H	17.3	17.5	17.7	18.0	18.5	17.3	17.5	17.8	18.0	18.5	
	8H	17.2	17.4	17.7	17.9	18.4	17.2	17.4	17.7	17.9	18.4	
Variations with the observer position at spacing:												
S =		1.0H	5.2 / -12.6					5.2 / -12.6				
		1.5H	8.0 / -14.5					8.0 / -14.5				
		2.0H	10.0 / -15.7					10.0 / -15.7				