Product code

Technical description

iGuzzini

Last information update: June 2025

Product configuration: PV68

PV68: Robin spotlight Ø37 for installation on a 48V low voltage track - DALI Powerline


PV68: Robin spotlight Ø37 for installation on a 48V low voltage track - DALI Powerline

free system for connecting the adapter electrically and mechanically to the track.

Installation On a low voltage Filorail track. A tool-free system for connecting the product electrically and mechanically to the track.

	U .	•	•	
Colour White (01) Black (04)	Weight (Kg) 0.2			

Miniaturised adjustable spotlight with adapter for installation on a 48V Filorail low voltage track. The thermoplastic adapters are designed so they can be installed even in the curved track sections. Die-cast aluminium body with an ideal passive dissipation system to guarantee a long life and effective heat management. Driver circuit with DALI Powerline technology that allows each spotlight on the track to be adjusted independently. This offers a remarkable level of flexibility and lighting control. The swivel joints allow the spotlight to be rotated by 360° and tilted by 160°. The set back position of the optic unit guarantees a high level of visual comfort. A high definition thermoplastic lens with the option of using additional accessories to create other light effects. A rapid tool-



Wiring LED driver integrated in product body - direct connection on 48V track. Track power supply unit to be ordered separately.



Complies with EN60598-1 and pertinent regulations

Technical data			
Im system:	516	Colour temperature [K]:	2700
W system:	10.9	MacAdam Step:	2
Im source:	860	Life Time LED 1:	> 50,000h - L90 - B10 (Ta 25°C)
W source:	9.6	Voltage [Vin]:	48
Luminous efficiency (Im/W,	47.3	Lamp code:	LED
real value):		Number of lamps for optical	1
Im in emergency mode:	-	assembly:	
Total light flux at or above	0	ZVEI Code:	LED
an angle of 90° [Lm]:		Number of optical	1
Light Output Ratio (L.O.R.)	60	assemblies:	
[%]:		Power factor:	See installation instructions
Beam angle [°]:	45°	Control:	DALI
CRI (minimum):	90		

Polar

Imax=938 cd	CIE	Lux			
90° 180°	nL 0.60 0° 97-100-100-100-60	h	d	Em	Emax
	UGR 18.0-18.0 DIN A.61	1	0.8	733	938
1050	UTE 0.60A+0.00T F"1=975	2	1.7	183	235
	F"1+F"2=999 F"1+F"2+F"3=1000 CIBSE	3	2.5	81	104
α=45°	LG3 L<1500 cd/m ² at 65° UGR<19 L<1500 cd/mq (@65° 4	3.3	46	59

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	54	51	49	47	50	48	48	46	77
1.0	56	53	51	50	53	51	51	49	81
1.5	59	57	55	54	56	55	54	53	88
2.0	61	59	58	57	59	58	57	55	92
2.5	62	61	60	59	60	59	59	57	95
3.0	63	62	61	61	61	61	60	58	97
4.0	64	63	63	62	62	62	61	59	99
5.0	64	64	63	63	63	62	61	60	100

Luminance curve limit

QC	A G	1.15 1.50	2000	1000 2000	500 1000	750	<-300 500	<=300	
	С	1.85			2000		1000	500	<=300
85° 75° 65°	~~								864
55°									a, h
45° 10	2	2	3 4 5	6 8 1	0 ³	2 3	4 5 6	8 10 ⁴	cd/m ²
C	0-180					C90-270 -			

UGR diagram

Riflect ceil/ca walls work Room x 2H	р. dim у 2H 3H 4H 6H 8H	0.70 0.50 0.20 18.6 18.4 18.3 18.3	19.2 19.0	0.50 0.50 0.20 viewed crosswise 18.8 18.7	0.50 0.30 0.20 e	0.30 0.30 0.20	0.70 0.50 0.20	0.70 0.30 0.20	0.50 0.50 0.20 viewed endwise	0.50 0.30 0.20	0.30 0.30 0.20
walls work Room X	pl. dim y 2H 3H 4H 6H 8H	0.50 0.20 18.6 18.4 18.3	0.30 0.20 19.2 19.0	0.50 0.20 viewed crosswis 18.8	0.30 0.20 e	0.30	0.50	0.30 0.20	0.50 0.20 viewed	0.30 0.20	0.30
work Room x	2H 3H 4H 6H 8H	0.20 18.6 18.4 18.3	0.20 0 19.2 19.0	0.20 viewed crosswis 18.8	0.20 e			0.20	0.20 viewed	0.20	
Room x	2H 3H 4H 6H 8H	18.6 18.4 18.3	19.2 19.0	viewed rosswis 18.8	e	0.20	020		viewed		0.20
x	y 2H 3H 4H 6H 8H	18.4 18.3	19.2 19.0	eiweeor: 18.8							
2H	3H 4H 6H 8H	18.4 18.3	19.0		19.4						
	4H 6H 8H	18.3		187		19.7	18.6	19.2	18.8	19.4	19.7
	6H 8H	1000	10.0	10.7	19.3	19.5	18.4	19.0	18.7	19.3	19.0
	8H	18.3	18.9	18.7	19.2	19.5	18.4	18.9	18.7	19.2	19.5
			18.8	18.6	19.1	19.4	18.3	18.8	18.6	19.1	19.4
	4011	18.2	18.7	18.6	19.0	19.4	18.2	18.7	18.6	19.0	19.4
	12H	18.2	18.6	<mark>18.</mark> 6	19.0	19.3	18.2	18.7	18.6	19.0	19.3
4H	2H	18.4	18.9	18.7	19.2	19.5	18.3	18.9	18.7	19.2	19.5
	3H	18.2	18.7	18.6	19.0	19.3	18.2	18.7	18.6	19.0	19.3
	4H	18.1	18.5	18.5	18.9	19.3	18.1	18.5	18.5	18.9	19.3
	6H	18.0	18.4	18.5	18.8	19.2	18.0	18.4	18.5	18.8	19.3
	8H	18.0	18.3	18.4	18.7	19.1	18.0	18.3	18.4	18.7	19.1
	12H	17.9	18.2	18.4	18.6	19.1	17.9	18.2	18.4	18.6	19.
вн	4H	18.0	18.3	18.4	18.7	19.1	18.0	18.3	18.4	18.7	19.
	6H	17.9	18.1	18.4	18.6	19.1	17.9	18.1	18.4	18.6	19.
	8H	17.8	18.1	18.3	18.5	19.0	17.8	18.1	18.3	18.5	19.0
	12H	17.8	18.0	18.3	18.5	19.0	17.8	18.0	18.3	18.5	19.0
12H	4H	17.9	18.2	18.4	18.6	19.1	17.9	18.2	18.4	18.6	19.
	6H	17.8	18.1	18.3	18.5	19.0	17.8	18.1	18.3	18.5	19.0
	8H	17.8	18.0	18.3	18.5	19.0	17.8	18.0	18.3	18.5	19.0
Variat	ions wi	th the ot	oserver p	osition a	at spacin	ig:					
S =	1.0H		5	.2 / -8	8			5	.2 / -8.	8	
	1.5H		8.	0 / -22	.1			8.	0 / -22	.1	