iGuzzini

Last information update: June 2025

Product configuration: PV95.01

PV95.01: Robin spotlight Ø51 for installation on a 48V low voltage track - DALI Powerline - 18W 1295lm - 4000K - CRI 90 - White



Product code

PV95.01: Robin spotlight Ø51 for installation on a 48V low voltage track - DALI Powerline - 18W 1295lm - 4000K - CRI 90 - White

Technical description

Miniaturised adjustable spotlight with adapter for installation on a 48V Filorail low voltage track. The thermoplastic adapters are designed so they can be installed even in the curved track sections. Die-cast aluminium body with an ideal passive dissipation system to guarantee a long life and effective heat management. Driver circuit with DALI Powerline technology that allows each spotlight on the track to be adjusted independently. This offers a remarkable level of flexibility and lighting control. The swivel joints allow the spotlight to be rotated by 360° and tilted by 160°. The set back position of the optic unit guarantees a high level of visual comfort. A high definition thermoplastic lens with the option of using additional accessories to create other light effects. A rapid toolfree system for connecting the adapter electrically and mechanically to the track.

Installation

On a low voltage Filorail track. A tool-free system for connecting the product electrically and mechanically to the track.

Colour White (01) Weight (Kg) 0.45

Wiring

LED diver integrated in product body - direct connection on 48V track. Track power supply unit to be ordered separately.

Complies with EN60598-1 and pertinent regulations







Technical data					
Im system:	1295	Colour temperature [K]:	4000		
W system:	18	MacAdam Step:	2		
Im source:	1750	Life Time LED 1:	> 50,000h - L90 - B10 (Ta 25°C)		
W source:	17	Voltage [Vin]:	48		
Luminous efficiency (lm/W,	71.9	Lamp code:	LED		
real value):		Number of lamps for optical	1		
Im in emergency mode:	-	assembly:			
Total light flux at or above	0	ZVEI Code:	LED		
an angle of 90° [Lm]:		Number of optical	1		
Light Output Ratio (L.O.R.)	74	assemblies:			
[%]:		Power factor:	See installation instructions		
Beam angle [°]:	46°	Control:	DALI		
CRI (minimum):	90				


Polar

	ie.	Lux			
90° (180°) '90° 98	L 0.74 8-100-100-100-74 JGR 19.7-19.7	h	d	Em	Emax
D	NOIN 0.61 DTE	2	1.7	432	555
K V T V No.	.74A+0.00T "1=979	4	3.4	108	139
F	"1+F"2=999 "1+F"2+F"3=1000 CIBSE	6	5.1	48	62
	G3 L<3000 cd/m ² at 65°	8	6.7	27	35

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	66	63	60	58	62	60	59	57	77
1.0	69	66	64	62	65	63	63	60	82
1.5	73	70	69	67	70	68	67	65	88
2.0	75	73	72	71	72	71	70	68	92
2.5	77	75	74	73	74	73	72	70	95
3.0	78	77	76	75	75	75	74	72	97
4.0	78	78	77	77	77	76	75	73	99
5.0	79	78	78	78	77	77	76	74	100

Luminance curve limit



Corre	cted UC	R value	at 1750) Im bar	e lamp lu	ım inous	flux)					
Rifled	et.:											
ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30	
walls work pl. Room dim		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30	
		0.20		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	
		viewed					viewed					
X	У	crosswise					endwise					
2H	2H	20.2	20.8	20.5	21.0	21.3	20.2	20.8	20.5	21.0	21.	
	ЗН	20.1	20.6	20.4	20.9	21.2	20.1	20.6	20.4	20.9	21.	
	4H	20.0	20.5	20.4	8.02	21.1	20.0	20.5	20.4	8.02	21.	
	бН	20.0	20.4	20.3	20.7	21.0	20.0	20.4	20.3	20.7	21.	
	HS	19.9	20.4	20.3	20.7	21.0	19.9	20.4	20.3	20.7	21.	
	12H	19.9	20.3	20.3	20.6	21.0	19.9	20.3	20.3	20.6	21.	
4H	2H	20.0	20.5	20.4	20.8	21.1	20.0	20.5	20.4	20.8	21.	
	ЗН	19.9	20.3	20.3	20.6	21.0	19.9	20.3	20.3	20.6	21.	
	4H	19.8	20.2	20.2	20.5	20.9	19.8	20.2	20.2	20.5	20.	
	6H	19.7	20.0	20.1	20.4	20.8	19.7	20.0	20.1	20.4	20.	
	HS	19.7	20.0	20.1	20.4	20.8	19.7	20.0	20.1	20.4	20.	
	12H	19.6	19.9	20.1	20.3	20.8	19.6	19.9	20.1	20.3	20	
вн	4H	19.7	20.0	20.1	20.4	20.8	19.7	20.0	20.1	20.4	20.	
	6H	19.6	19.8	20.0	20.3	20.7	19.6	19.8	20.0	20.3	20	
	HS	19.5	19.7	20.0	20.2	20.7	19.5	19.7	20.0	20.2	20.	
	12H	19.5	19.6	20.0	20.1	20.7	19.5	19.6	20.0	20.1	20.	
12H	4H	19.6	19.9	20.1	20.3	20.8	19.6	19.9	20.1	20.3	20.	
	6H	19.5	19.7	20.0	20.2	20.7	19.5	19.7	20.0	20.2	20.	
	HS	19.5	19.6	20.0	20.1	20.7	19.5	19.6	20.0	20.1	20.	
Varia	tions wi	th the ob	server p	osition	at spacin	g:						
S =	1.0H		5.4 / -13.1					5.4 / -13.1				
	1.5H		8.2 / -16.8					8.2 / -16.8				
	2.0H	10.2 / -20.4					10.2 / -20.4					