


Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	64	59	56	54	58	56	55	52	70
1.0	67	63	60	58	62	60	59	56	75
1.5	72	69	66	64	68	66	65	62	83
2.0	75	72	70	69	71	70	69	66	88
2.5	76	74	73	72	73	72	71	69	92
3.0	77	76	75	74	75	74	73	71	94
4.0	79	77	77	76	76	75	74	72	96
5.0	79	78	78	77	77	76	75	73	97

Luminance curve limit



UGR diagram

Corrected UGR values (at 2100 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	18.7	19.4	19.0	19.6	19.9	18.7	19.4	19.0	19.6	19.9
	3H	18.7	19.3	19.1	19.6	19.9	18.8	19.4	19.1	19.6	19.9
	4H	18.7	19.3	19.1	19.6	19.9	18.7	19.3	19.1	19.6	19.9
	6H	18.7	19.3	19.1	19.6	19.9	18.7	19.2	19.0	19.5	19.8
	8H	18.7	19.3	19.1	19.6	19.9	18.6	19.1	19.0	19.5	19.8
12H	18.7	19.2	19.1	19.6	19.9	18.6	19.1	19.0	19.4	19.8	
4H	2H	18.7	19.3	19.1	19.6	19.9	18.7	19.3	19.1	19.6	19.9
	3H	18.8	19.3	19.2	19.6	20.0	18.8	19.3	19.2	19.7	20.0
	4H	18.8	19.3	19.2	19.6	20.0	18.8	19.3	19.2	19.6	20.0
	6H	18.9	19.2	19.3	19.6	20.1	18.8	19.2	19.2	19.6	20.0
	8H	18.9	19.2	19.3	19.6	20.1	18.8	19.1	19.2	19.5	20.0
12H	18.9	19.2	19.3	19.6	20.1	18.7	19.0	19.2	19.5	19.9	
8H	4H	18.8	19.1	19.2	19.5	20.0	18.9	19.2	19.3	19.6	20.1
	6H	18.9	19.1	19.3	19.6	20.1	18.9	19.2	19.4	19.6	20.1
	8H	18.9	19.1	19.4	19.6	20.1	18.9	19.1	19.4	19.6	20.1
	12H	18.9	19.1	19.4	19.6	20.1	18.9	19.1	19.4	19.6	20.1
12H	4H	18.7	19.0	19.2	19.5	19.9	18.9	19.2	19.3	19.6	20.1
	6H	18.8	19.1	19.3	19.5	20.0	18.9	19.1	19.4	19.6	20.1
	8H	18.9	19.1	19.4	19.6	20.1	18.9	19.1	19.4	19.6	20.1
Variations with the observer position at spacing:											
S =	1.0H	1.4 / -1.5				1.4 / -1.5					
	1.5H	3.1 / -3.7				3.1 / -3.7					
	2.0H	4.8 / -4.9				4.8 / -4.9					