Design iGuzzini

iGuzzini

Last information update: June 2023

Product configuration: P894

P894: Deep Frame - 1 element - CoB warm LED- spot beam



Product code

P894: Deep Frame - 1 element - CoB warm LED- spot beam Attention! Code no longer in production

Technical description

Individual recessed luminaire for LED lamp. Version with a perimeter frame. Shaped sheet steel structural frame. Die-cast aluminium, twin swivel universal joint located in a position set back from the installation surface to guarantee a high level of visual comfort. Tilts ± 30° around both the horizontal and vertical axes. Die-cast aluminium lighting body designed to optimise heat dispersal. High efficiency aluminium reflector - spot angle. High color rendering index, warm white LED lamp. Glass cover The installation system is toolfree. Control gear unit included.

Installation

Recessed in 1 to 30 mm thick false ceilings. Steel wire fixing springs. Preparation hole 102 x 102.

Colour

White (01) | Grey / Black (74)



Mounting ceiling recessed

Wiring

Complete with electronic control gear unit connected to the luminaire. Wiring for connecting to mains network on driver terminal board.

Notes

Accessories available: refractor for elliptical flow distribution - interchangeable reflectors.



Technical data			
Im system:	656	CRI (minimum):	90
W system:	10.1	Colour temperature [K]:	3000
Im source:	950	MacAdam Step:	3
W source:	8.4	Life Time LED 1:	> 50,000h - L80 - B10 (Ta 25°C)
Luminous efficiency (Im/W,	64.9	Ballast losses [W]:	1.7
real value):		Lamp code:	LED
Im in emergency mode:	-	Number of lamps for optical	1
Total light flux at or above	0	assembly:	
an angle of 90° [Lm]:		ZVEI Code:	LED
Light Output Ratio (L.O.R.) [%]:	69	Number of optical assemblies:	1
Beam angle [°]:	18°		

Polar

Imax=3951 cd	CIE	Lux			
90° 180° 90°	nL 0.69 99-100-100-100-69	h	d	Em	Emax
	UGR <10-<10 DIN A.61 UTE	2	0.6	773	988
$\langle \rangle$	0.69A+0.00T F"1=990	4	1.3	193	247
4000	F"1+F"2=999 F"1+F"2+F"3=1000	6	1.9	86	110
α=18°	LG3 L<1500 cd/m² at 65° UGR<10 I L<1500 cd/mq @	_{65°} 8	2.5	48	62

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	62	59	57	55	58	56	56	54	78
1.0	65	62	60	58	61	59	59	57	82
1.5	68	66	64	63	65	64	63	61	88
2.0	70	69	67	66	68	67	66	64	93
2.5	72	70	69	69	69	68	68	66	95
3.0	72	72	71	70	70	70	69	67	97
4.0	73	73	72	72	71	71	70	68	99
5.0	74	73	73	73	72	72	71	69	100

Luminance curve limit

QC	Α	G	1.15	200	0	10	00	500		<	300		
	в		1.50			20	00	1000	750	50	00	<-300	
	С		1.85					2000		10	00	500	<-300
85° 75° 65° 55°	0 ²		2	3 4		6	8 10	2	2 3	4 5	6	8 104	s 6 4 2 a h cd/m ²
	C0-18	0	-	100	-	_			C90-270				

UGR diagram

Riflect. ceil/cav walls work p Room (x 2H 4H	v dim y 2H 3H 4H 6H 8H 12H	0.70 0.50 0.20 1.4 1.3 1.3 1.2 1.2 1.1	0.70 0.30 0.20 3.5 2.9 2.6 2.2 2.2	0.50 0.20 viewed crosswise 1.8 1.7 1.6 1.6	3.8 3.2	0.30 0.30 0.20 4.2 3.6	0.70 0.50 0.20	3.5	0.50 0.50 0.20 viewed endwise		0.30 0.30 0.20
walls work p Room x 2H	ol. dim y 2H 3H 4H 6H 8H 12H	0.20 1.4 1.3 1.3 1.2 1.2	0.20 3.5 2.9 2.6 2.2	0.20 viewed crosswis 1.8 1.7 1.6	0.20 e 3.8 3.2	0.20 4.2	0.20 1.4	0.20	0.20 viewed endwise 1.8	0.30 0.20	0.30 0.20 4.2
work p Room x 2H	dim y 2H 3H 4H 6H 8H 12H	0.20 1.4 1.3 1.3 1.2 1.2	0.20 3.5 2.9 2.6 2.2	0.20 viewed crosswis 1.8 1.7 1.6	0.20 e 3.8 3.2	0.20 4.2	0.20 1.4	0.20	0.20 viewed endwise 1.8	0.20 	0.20
х 2Н	У 2H 3H 4H 6H 8H 12H	1.3 1.3 1.2 1.2	3.5 2.9 2.6 2.2	1.8 1.7 1.6	3.8 3.2			3.5	endwise 1.8	3.8	
2Н	2H 3H 4H 6H 8H 12H	1.3 1.3 1.2 1.2	3.5 2.9 2.6 2.2	1.8 1.7 1.6	3.8 3.2			3.5	1.8	3.8	
200	3H 4H 6H 8H 12H	1.3 1.3 1.2 1.2	2.9 2.6 2.2	1.7 1.6	3.2						
4H	4н 6н 8н 12н	1.3 1.2 1.2	2.6 2.2	1.6		3.6	14	2.0		22	2.2
4H	6Н 8Н 12Н	1.2 1.2	2.2		20		1.4	2.9	1.7	0.0	3.0
4H	8Н 12Н	1.2		16	2.9	3.3	1.3	2.6	1.7	3.0	3.3
4H	<mark>12</mark> H		22	1.0	2.6	2.9	1.3	2.3	1.7	2.6	3.0
4H	100000	<mark>1.1</mark>	L .L	1.6	2.6	2.9	1.2	2.3	1.6	2.6	3.0
4H	022835		2.2	1.5	2.5	2.9	1.2	2.2	1.6	2.6	3.0
	2H	1.3	2.6	1.7	3.0	3.3	1.3	2.6	1.6	2.9	3.3
	3H	1.2	2.3	1.6	2.6	3.0	1.2	2.3	1.6	2.6	3.0
	4H	1.1	2.2	1.5	2.6	3.0	1.1	2.2	1.5	2.6	3.0
	6H	0.7	2.5	1.2	2.9	3.4	0.7	2.5	1.2	2.9	3.4
	HS	0.6	2.5	1.1	3.0	3.5	0.6	2.5	1.1	3.0	3.5
	12H	0.5	2.5	1.0	3.0	3.5	0.5	2.5	1.0	2.9	3.5
вн	4H	0.6	2.5	1.1	3.0	3.5	0.6	2.5	1.1	3.0	3.5
	6H	0.5	2.3	1.0	2.8	3.3	0.5	2.3	1.0	2.8	3.3
	8H	0.5	2.1	1.0	2.6	3.1	0.5	2.1	1.0	2.6	3.1
	12H	0.7	1.6	1.2	2.1	2.7	0.7	1.6	1.2	2.1	2.7
12H	4H	0.5	2.5	1.0	2.9	3.5	0.5	2.5	1.0	3.0	3.5
	6H	0.5	2.1	1.0	2.6	3.1	0.5	2.1	1.0	2.6	3.1
	8H	0.7	1.6	1.2	2.1	2.7	0.7	1.6	1.2	2.1	2.7
Variatio	ions wi	th the ol	oserverp	osition	at spacir	ng:	020				
S =	1.0H		3	.4 / -4	4	3.4 / -4.4					
	1.5H		5	.9 / -6	9	5.9 / -6.9					