




**Coefficientes de uso**

R	77	75	73	71	55	53	33	00	DRR
K0.8	60	53	49	46	49	46	43	36	64
1.0	65	59	55	51	54	51	47	40	70
1.5	71	67	63	60	61	58	54	46	80
2.0	75	71	68	66	65	63	58	49	86
2.5	77	74	72	70	68	66	60	51	90
3.0	79	76	74	72	69	68	62	52	92
4.0	80	78	77	75	71	70	63	54	94
5.0	81	80	78	77	72	71	64	54	95

**Curva límite de luminancia**



**Diagrama UGR**

Photometric curve code: 66000001.044  
 Uncorrected UGR values (at 1000 lm bare lamp luminous flux)

Reflect.:		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
ceiling		0.70	0.70	0.50	0.50	0.30	0.50	0.30	0.50	0.30	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.20	0.20	0.20	0.20	0.20
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim		viewed					viewed				
x	y	crosswise					endwise				
2H	2H	7.8	8.4	8.8	9.1	9.9	9.2	9.7	9.9	10.4	11.3
	3H	7.8	8.1	8.4	8.8	9.7	9.0	9.4	9.8	10.2	11.1
	4H	7.5	7.9	8.3	8.7	9.6	8.9	9.3	9.7	10.1	11.0
	6H	7.4	7.8	8.2	8.6	9.5	8.7	9.1	9.6	9.9	10.9
	8H	7.3	7.7	8.2	8.5	9.5	8.7	9.1	9.5	9.9	10.9
12H	7.3	7.6	8.1	8.4	9.4	8.6	9.0	9.5	9.8	10.8	
4H	2H	7.8	8.0	8.4	8.8	9.7	8.9	9.3	9.7	10.1	11.0
	3H	7.3	7.7	8.2	8.5	9.5	8.6	9.0	9.5	9.8	10.8
	4H	7.2	7.5	8.1	8.3	9.4	8.5	8.8	9.4	9.6	10.7
	6H	7.1	7.3	7.9	8.2	9.3	8.4	8.6	9.3	9.5	10.6
	8H	7.0	7.2	7.9	8.1	9.2	8.3	8.6	9.2	9.4	10.5
12H	6.9	7.2	7.8	8.0	9.1	8.2	8.5	9.1	9.3	10.4	
8H	4H	7.0	7.2	7.9	8.1	9.2	8.3	8.6	9.2	9.4	10.5
	6H	6.9	7.1	7.8	8.0	9.1	8.2	8.4	9.1	9.3	10.4
	8H	6.8	7.0	7.7	7.9	9.0	8.1	8.3	9.0	9.2	10.3
	12H	6.7	6.9	7.7	7.8	8.9	8.0	8.2	9.0	9.1	10.3
12H	4H	6.9	7.2	7.8	8.0	9.1	8.2	8.5	9.1	9.4	10.4
	6H	6.8	7.0	7.7	7.9	9.0	8.1	8.3	9.0	9.2	10.3
	8H	6.7	6.9	7.7	7.8	8.9	8.0	8.2	9.0	9.1	10.3
Variations with the observer position at spacing:											
S =	1.0H	3.1 / -12.3					1.4 / -4.6				
	1.5H	5.4 / -19.1					3.9 / -16.4				
	2.0H	7.4 / -19.7					5.9 / -18.0				